

**WIRING DIAGRAM
FOR REMOTE CHANNEL
LETTERS W/ LED'S &
SNAP IN BUSHING.**

FOR LED APPLICATIONS, ALL SECONDARY LEADS
AND CONNECTIONS DO NOT
REQUIRE CONDUIT, OR SPLICE
BOXES WHEN INSTALLED ACCORDING TO
NEC 600 & LOCAL CODES

(Bonding ground not required according to 2011 NEC 600)
(Wet rated power supplies may not require separate enclosures,
refer to and follow power supply manufacturer requirements included)

